
EGANVILLE DRINKING WATER SYSTEM

2015 ANNUAL
SUMMARY REPORT

Township of Bonnechere Valley
Water and Sewage Department
February 2016



Eganville Drinking Water System – 2015 Annual Summary Report

Table of Contents

Executive Summary..... 1

Introduction 2

Report Availability..... 3

Eganville Drinking Water System..... 3

Summary of Adverse Test Results and Other Issues 4

Summary of Test Results..... 4

 Microbiological Testing..... 4

 Operational Testing..... 4

 Summary of Schedule 15.1 Lead Testing 5

 Summary of Schedule 23 Inorganic Parameters..... 6

 Summary of Schedule 24 Organic Parameters 6

Major Infrastructure Improvements..... 8

Water Usage Summary 8



Executive Summary

The water delivered to the customers of the Eganville Drinking Water System continues to be safe and meet all water quality standards. There were no adverse water quality incidents in 2015. The Inorganic and Organic parameters tested for in 2015 were well within Maximum Acceptable Concentrations as listed in the Ontario Drinking Water Quality Standards.

All reports required by applicable acts, regulations, permits and licences have been prepared and submitted in accordance with the legislation.

All sampling required by applicable acts, regulations, permits and licences has been conducted in accordance with the legislation.

The volume of water treated and distributed to the Village of Eganville customers averaged 549m³/day which is 26% of the rated capacity of the Eganville Water Treatment Plant.

The maximum daily flow of 838 m³ occurred in February, due to a watermain break, which is approximately 40% of the rated capacity of the Eganville Water Treatment Plant.



Eganville Drinking Water System – 2015 Annual Summary Report

Introduction

The treatment and delivery of potable water in Ontario is regulated by the Ministry of the Environment (MOE) under the Safe Drinking Water Act. On June 1, 2003 O. Reg. 170/03 came into effect which prescribes requirements for owners and operators of municipal drinking water systems.

O. Reg. 170/03 requires the owner to produce an Annual Report, under Section 11. The Report must include the following:

- ✚ A description of the drinking water system including a list of the water treatment chemicals used;
- ✚ A summary of any adverse water quality reports and corrective actions;
- ✚ A summary of all required testing results;
- ✚ A description of any mayor expenses incurred to install, repair or replace equipment.

Every time an Annual Report is prepared the owner of the system shall ensure that effective steps are taken to advise users of water from the system that copies of the report are available, without charge, and how a copy may be obtained.

The Regulation also requires the owner to produce a Summary Report as indicated in Schedule 22.

- ✚ The report must list the requirements of the Act, its Regulations, the system's Drinking Water Works Permit, Municipal Drinking Water Licence and any orders the system failed to meet during the reporting period. The report must also specify the duration of the failure, and for each failure referred to, describe the measures that were taken to correct the failure.
- ✚ To enable the Owner to assess the rated capacity of their system to meet existing and future planned water uses, the following information is also required in the report.
 - A summary of the quantities and flow rates of water supplied during the reporting period, including the monthly average and maximum daily flows;
 - A comparison of the summary to the rated capacity and flow rates approved in the system's Permit To Take Water, Drinking Water Works Permit and Municipal Drinking Water Licence



Eganville Drinking Water System – 2015 Annual Summary Report

Report Availability

A copy of this report shall be given, without charge, to every person who requests a copy from the Township of Bonnechere Valley Municipal Office at 49 Bonnechere St. E., Eganville, Ontario.

Users of the system in the Village of Eganville shall be advised of the availability of the report by providing an insert into their monthly water bill.

The report shall also be available on the Township of Bonnechere Valley website at www.bonnecherevalleytwp.com

Eganville Drinking Water System

The Eganville Water System is owned and operated by the Township of Bonnechere Valley and provides a potable water supply to the residents and business of the Village of Eganville. The system generally consists of a Water Treatment Plant (WTP), a distribution system and a water standpipe.

The WTP, built in 1990, treats water from the Bonnechere River with two Graver Monoplant Package Units, which have a combined capacity of 2,070 m³/day. The distribution system, originally constructed in the mid 1970's consists of approximately 13 km of piping ranging in diameter from 150 mm to 250 mm with a 300,000 Imperial gallon (1,363 m³) capacity steel standpipe for pressure equalization and supply.

The water treatment process within the two Graver Monoplant Package Units uses Sodium Hypochlorite for pre-disinfection and Pre Hydroxylated Aluminum Sulphate with Polyelectrolyte for coagulation. The treated and filtered water is then disinfected with Sodium Hypochlorite prior to being pumped out to the distribution system.

Large Residential Drinking Water System	
Name	Eganville Drinking Water System
Owner	Township of Bonnechere Valley
Number	210000675
Municipal Drinking Water Licence	171-101
Drinking Water Works Permit	171-201
Permit To Take Water	2101-8W4LN3
Financial Plan	171-301
QMS Operational Plan	171-401



Eganville Drinking Water System – 2015 Annual Summary Report

Summary of Adverse Test Results and Other Issues

There were no adverse test results or other regulatory issues in 2015.

Summary of Test Results

Microbiological Testing

Source	Number of Samples	Range of E. Coli Results (CFU/100ml) (min #-max #)	Range of Total Coliform Results (CFU/100ml) (min #-max #)	ODWQS*
Raw	52	1-29	1-220	N/A
Treated	52	0	0	0
Distribution	181	0	0	0

* ODWQS – Ontario Drinking Water Quality Standard, Ont. Reg. 169/03

Source	Number of HPC* Samples	Range of HPC Results (CFU/mL) (min#-max#)	ODWQS
Raw	0	N/A	N/A
Treated	52	<2-20	500
Distribution	181	<2-42	500

*HPC - Heterotrophic Plate Count

Operational Testing

Parameter	Number of Samples	Range of Results (min #)-(max #)	ODWQS
Turbidity (4 dual media filters & 2 GAC filters)	8760 per filter	<0.3 greater than 90% of the time & <1.0 100% of the time	1.0 NTU*
Free Chlorine Residual in water entering distribution system	8760	1.42 – 2.54 mg/L	0.05 - 4.0 mg/L
Total Chlorine Residual in water entering distribution system	8760	1.76 – 2.68 mg/L	N/A
Free Chlorine Residual in distribution system	181	1.21 – 2.12 mg/L	0.05 - 4.0 mg/L
Total Chlorine Residual in distribution system	181	1.38 – 2.20 mg/L	N/A

*NTU – Nephelometric Turbidity Unit



Eganville Drinking Water System – 2015 Annual Summary Report

Summary of Schedule 15.1 Lead Testing

Sample Period	Sample Date	Location	Sample Results		
			Lead* mg/L	Alkalinity mg/L	pH
December 2013 to April 2014	April 1, 2014	Hydrant #0061 313 Jessie St.	N/A	33	6.88
December 2013 to April 2014	April 1, 2014	Hydrant #0031 244 Oak St.	N/A	35	6.92
June to October 2014	Oct. 9, 2014	Hydrant #0015 90 Mill St.	N/A	28	7.28
June to October 2014	Oct. 9, 2014	Hydrant #0043 78 Queen St.	N/A	29	7.35
December 2014 to April 2015	April 1, 2015	Hydrant #0041 5 Foran St.	N/A	31	7.20
December 2014 to April 2015	April 1, 2015	Hydrant #0024 98 Hartwig St.	N/A	29	7.17
June to October 2015	Sept. 8, 2015	Hydrant #0007 46 Bonnechere St.	0.00002	24	7.25
June to October 2015	Sept. 8, 2015	Hydrant #0043 68 Queen St.	0.00009	25	7.33

*ODWQS standard for lead in drinking water is 0.01 mg/L



Eganville Drinking Water System – 2015 Annual Summary Report

Summary of Schedule 23 Inorganic Parameters

The treated water was sampled on January 27, 2015 for the following inorganic parameters. No exceedance of the ODWQS was noted.

Inorganic Parameter	Results (mg/L)	ODWQS (mg/L)
Antimony	<0.0001	0.006
Arsenic	0.0002	0.025
Barium	0.026	1.0
Boron	0.007	5.0
Cadmium	<0.00002	0.005
Chromium	0.002	0.05
Mercury	<0.00002	0.00.
Selenium	<0.001	0.01
Uranium	<0.00005	0.02
Other Parameters		
Lead	0.00007	0.01
Sodium	6.7	200
Fluoride	<0.1	1.5
Nitrite	<0.1	1.0
Nitrate	0.1	10.0

Summary of Schedule 24 Organic Parameters

The treated water was sampled on January 27, 2015 for the following organic parameters. No exceedance of the ODWQS was noted.

Organic Parameter	Result (ug/L)	ODWQS (ug/L)
Alachlor	<0.3	5
Aldicarb	< 3	9
Aldrin + Dieldrin	<0.02	0.7
Atrazine + N-dealkylated metabolites	<0.5	5
Azinphos-methyl	<1	20
Bendiocarb	<3	40
Benzene	<0.5	5
Benzo(a)pyrene	<0.005	0.01
Bromoxynil	<0.3	5
Carbaryl	<3	90
Carbofuran	<1	90
Carbon Tetrachloride	<0.2	5
Chlordane (Total)	<0.04	7



Eganville Drinking Water System - 2015 Annual Summary Report

Organic Parameter	Result (ug/L)	ODWQS (ug/L)
Chlorpyrifos	<0.5	90
Cyanazine	<0.5	10
Diazinon	<1	20
Dicamba	<5	120
1,2-Dichlorobenzene	<0.1	200
1,4-Dichlorobenzene	<0.2	5
Dichlorodiphenyltrichloroethane (DDT) + metabolites	<0.01	30
1,2-Dichloroethane	<0.1	5
1,1-Dichloroethane	N/A	14
Dichloromethane	<0.3	50
2,4 Dichlorophenol	<0.1	900
2,4-Dichlorophenoxy acetic acid (2,4-D)	<5	100
Diclofop-methyl	<0.5	9
Dimethoate	<1	20
Dinoseb	<0.5	10
Diquat	<5	70
Diuron	<5	150
Glyphosate	<25	280
Heptachlor + Heptachlor Epoxide	<0.1	3
Lindane (Total)	<0.1	4
Malathion	<5	190
Methoxychlor	<0.1	900
Metolachlor	<3	50
Metribuzin	<3	80
Monochlorobenzene	<0.2	80
Paraquat	<1	10
Parathion	<3	50
Pentachlorophenol	<0.1	60
Phorate	<0.3	2
Picloram	<5	190
Polychlorinated Biphenyls(PCB)	<0.05	3
Prometryne	<0.1	1
Simazine	<0.5	10
THM (Oct 27 latest annual running average)	62.9	100
Temephos	<10	280
Terbufos	<0.3	1
Tetrachloroethylene	<0.2	30
2,3,4,6-Tetrachlorophenol	<0.1	100
Triallate	<10	230
Trichloroethylene	<0.1	5
2,4,6-Trichlorophenol	<0.1	5
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	<10	280
Trifluralin	<0.5	45
Vinyl Chloride	<0.2	2



Eganville Drinking Water System – 2015 Annual Summary Report

Major Infrastructure Improvements

During 2015 the Eganville Drinking Water System did not have any major infrastructure improvements.

Water Usage Summary

2015 Month	Average Day m ³	Maximum Day m ³	Monthly Total m ³
January	498	690	15446
February	540	838*	15112
March	585	718	18124
April	583	763	17492
May	584	689	18115
June	533	636	15981
July	558	676	17284
August	561	667	17398
September	623	807**	18675
October	533	619	16533
November	512	590	15351
December	475	532	14738
Total			200249
Average	549	685	16687

Note: * higher flows due to watermain break, ** higher flows due to service line breaks

The rated capacity of the Eganville Water Treatment Plant is 2070 m³/day.

The average day flow during 2015 was 549 m³ which is only 26% of the rated capacity.

The maximum daily flow recorded during 2015 was 838 m³ which is only 40% of the rated capacity.

Based on this the Eganville Water Treatment Plant has more than adequate capacity to supply the Village of Eganville with drinking water for the foreseeable future.